

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Current census was not available due to school closure for the summer. Maintenance staff were on site at time of inspection waxing and cleaning school floors.

- Hot water/ Utility Room: 118°F
- Light intensity/ Classrooms: 44-Fc to 78-Fc

Email Address(es): torossian@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

-Repair holes in the wall tiles inside male bathroom #227 left by implements that were previously placed there.

-Provide missing ceiling panels inside classrooms #109 and #103.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

-Replace two burnt out light bulbs of ceiling lamps inside females bathroom #253 and males bathroom #253 to ensure correct light intensity.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #12. Toilet Facilities

-Observed two toilets covered with a black plastic bag. Repair toilets in females bathroom #162.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspection Conducted By: Juan Escudero (27326)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Miami Springs Senior H.
Date: 7/7/2020

Inspector Signature:

Client Signature:

Email to Client